



Sunland Park Fire Department

Daniel A. Medrano, Fire Chief

1000 McNutt Rd.

Sunland Park, NM 88063

575-268-6224

In accordance with the 2015 International Fire Code Section 503.2.4, the required turning radius of a fire apparatus access road shall be determined by the fire code official. As the Authority Having Jurisdiction and in accordance with the 2015 IFC I will require the following:

For all commercial and multi-residential buildings, the roads and curbing must meet the following minimum turning radiuses to meet the requirement of the fire apparatus.

- Inside turning radius of at least 25 feet
- Curb to curb turning radius of at least 41 feet
- Wall to wall turning radius of at least 48 feet

This information should be considered an addendum to my memorandum titled **Fire Department Access Roads** dated September 18, 2020.

Daniel Medrano
Fire Chief
Sunland Park Fire Department